

Summary of Water Samples

License Number: 7306

No. of samples required by licence	Date of water sample	Biochemical oxygen demand	Chlorine (free residual)	Conductivity	Faecal Coliforms	Nitrogen (total)	pH	Phosphorus (total)	Total Suspended Solids
4	21/05/2014	<2 mg/L	0.6 mg/L	803 microsiemens per centimetre	<1 CFU/100mL	5 mg/L	8.1 pH	7.38 mg/L	6 mg/L
4	2/07/2014	<2 mg/L	2.1 mg/L	784 microsiemens per centimetre	<2 CFU/100mL	3 mg/L	8.1 pH	7.04 mg/L	6 mg/L
4	9/12/2014	2 mg/L	<0.5 mg/L	806 microsiemens per centimetre	<2 CFU/100mL	9 mg/L	8.5 pH	7.73 mg/L	6 mg/L
4	20/05/2015	<2 mg/L	2.4 mg/L	805 microsiemens per centimetre	<1 CFU/100mL	5 mg/L	8.2 pH	8.53 mg/L	7 mg/L
4	16/09/2015	<2 mg/L	<0.5 mg/L	757 microsiemens per centimetre	<1 CFU/100mL	4 mg/L	8.6 pH	7.27 mg/L	4 mg/L